



**Office of the Mayor-President**  
Purchasing Division

City of Baton Rouge  
Parish of East Baton Rouge  
222 St. Louis Street, 8<sup>th</sup> Floor, RM 826  
P.O. Box 1471  
Baton Rouge, Louisiana 70821

225/389-3259 FAX 225/389-4841  
[purchasinginfo@brgov.com](mailto:purchasinginfo@brgov.com)

**Kris R. Goranson**  
Director of Purchasing

**Addendum No. 1**  
**Page 1 of 2**

**September 13, 2021**

Your reference is directed to **File Number: A21-0419**

**Solicitation Number: A21-0419 for:**  
**“Sump Pumps”**

which is scheduled to open at 11:00 a.m. CDT on September 17, 2021:

The following question and answer is made to the referenced solicitation:

1. Question: Referenced Proposal Request. Bid document on page 1, indicates the Proposals are due by 11:00 AM CST on 09/17/21. Since Daylight Savings Time does not end until 11/07/21, should that be 11:00 AM CDT  
**Answer: Proposal are to be received no later than 9/17/21 11:00 AM CDT.**
2. Question: Under ITEM 0003 Goulds 3886 – ½ HP PUMP OR APPROVED EQUAL, Page 13 “The casing shall be cast from ASTM A48 Class 25 gray Iron”. Goulds’ specifications identifies the casing material as “Class 30”. Class 30 has a greater tensile strength and a higher hardness.  
**Answer: Goulds specifications were updated to “Class 30” is correct.**
3. Question: Page 13 “The Impeller, casing, bearing/seal housing and motor cover shall be of ASTM A48 Class 25 high quality cast Iron”. As with the previous item Gould’s specifications call for “Class 30”.  
**Answer: Goulds specifications were updated to “Class 30” is correct.**
4. Question: Page 13, specification calls for “The pump/motor shaft wetted-end shall be series 400 Stainless Steel” Gould’s specification calls for “316SS”  
**Answer: Goulds specifications were updated to “316SS” is correct.**

This addendum is hereby officially made a part of the referenced solicitation and should be attached to the bidder’s proposal or otherwise acknowledged therein.

If you have already submitted your proposal and this addendum causes you to revise your original bid, please indicate changes herein and return to Purchasing prior to bid opening in an envelope marked with the file number, bid opening date, and time. If this addendum does not cause you to revise your bid, please acknowledge receipt of



**Office of the Mayor-President**  
Purchasing Division

City of Baton Rouge  
Parish of East Baton Rouge  
222 St. Louis Street, 8<sup>th</sup> Floor, RM 826  
P.O. Box 1471  
Baton Rouge, Louisiana 70821

225/389-3259 FAX 225/389-4841  
[purchasinginfo@brgov.com](mailto:purchasinginfo@brgov.com)

**Kris R. Goranson**  
Director of Purchasing

the addendum by signing your name and company below and returning it in accordance with the provisions above.

---

(Name and Signature)

Date

---

(Company Name)